

Testing Address
 z Example Company
 Head Office
 Jones Street
 Smithville
 Cornwall
 TR10 8BE

Printed: 15 March 2007

Testing Carried Out By
 Electratest Limited
 Ebenezer Hall
 Trevethan Road
 Falmouth
 Cornwall
 TR11 2AU

Account Ref: 13713-0499-0000



LOCATION	APP ID	APPLIANCE DESCRIPTION FAIL REASON - RECOMMENDATION	DATE TESTED	VISUAL CHECKS	EARTH Ohm	INSUL'N M Ohm	POLARITY CHECK	LOAD KVA	LEAKAGE mA	STATUS
ADMINISTRATION OFFICE										
	E00606287A	SUPPLY LEAD EARTH CONTINUITY FAIL - DISCARD	18/02/05	P	0.00 F	- S	P	0.00 S	0.00 S	FAIL
CUSTOMER SERVICE OFFICE										
	E00356845A	EXT CABLE 4 REVERSED POLARITY - DISCARD	17/02/05	P	0.00 S	- S	F	0.00 S	0.00 S	FAIL
FASTRACK OFFICE										
	E00356692	EXT CABLE 5 INSULATION RESISTANCE FAIL - DISCARD	15/02/05	P	0.16 P	0.24 F	P	0.00 S	0.00 S	FAIL
MAIN OFFICE AREA										
	E00806152	KETTLE INOPERATIVE - REPLACE / DISCARD	19/02/05	P	0.08 P	^50.0 P	S	0.00 F	0.00 S	FAIL
Total Appliances										4

THE ABOVE APPLIANCES MUST NOT BE USED UNTIL REPAIRED AND RETESTED